

ANNUAL REPORT

MAPLETON WASTEWATER POLLUTION CONTROL PLANT

FOR THE PERIOD:
JANUARY 1, 2021 – DECEMBER 31, 2021

*Prepared for the Township of Mapleton
by the Ontario Clean Water Agency*



Table of Contents

1.	System Description.....	2
2.	Influent and Effluent Monitoring and Comparison to Effluent Objectives and Effluent Limits	5
2.1	Influent (Raw Sewage)	5
2.1.1	Sampling Frequency: Influent	5
2.1.2	Influent (Raw Sewage) Monitoring Data.....	6
2.1.3	Historical Trends of Influent (Sewage) Characteristics and Influent Flowrates	6
2.2	Effluent and Flowrate.....	9
2.2.1	Sampling Frequency: Effluent.....	9
2.2.2	Effluent Monitoring Data	9
2.2.3	Effluent Objectives and Limits.....	10
2.2.4	Comparison of Data to Effluent Objectives and Effluent Limits	11
2.2.5	Effluent Flow and Maximum Discharge Rates.....	11
2.5	Overview of Success and Adequacy of the Works;.....	14
3.	Deviation from the Monitoring Schedule	14
4.	Operating Problems and Corrective Actions	14
5.	Major Maintenance Activities	14
6.	Effluent Quality Assurance and Control	15
7.	Calibration and Maintenance Procedures	15
8.	Efforts and Results Achieved in Meeting Effluent Objectives	16
9.	Sludge Generation.....	17
10.	Complaints	17
11.	By-pass, Spill or Abnormal Discharge Events	17
12.	Notice of Modifications	17
13.	Bypass/Overflow Proposed Elimination Projects	18
14.	Changes/updates to Scheduled Construction/Commissioning.....	18

Appendix A: 2021 Performance Assessment Report

Appendix B: 2022 Sampling Schedule

Appendix C: 2021 Calibration Reports

Appendix D: 2021 By-pass/Overflow/Spill Incident Report

1. System Description

The Mapleton wastewater facility receives residential and commercial wastewater and provides a level of treatment to meet the “Environmental Compliance Approval (ECA) #1391-B38PLA” for discharging into the Conestogo River.

Moorefield

Low-Pressure Sanitary Sewage Collection System (Off-site)

- Approximately 160 individual packaged grinder pump stations outside of the properties to be serviced including service laterals;
- Low-pressure collection sewers on Robb Street, Carson Street, Adam Brown Street, Maudsley Street, Ball Avenue, McGivern Street, Hillwood Drive, Booth Street West and Eight Concession Road;

Booth Street Sanitary Pumping Station (Off-site)

- A sewage pumping station located on Booth Street consists of a 2.4 m diameter by 4.5 m deep wet well equipped with two (2) submersible sewage pumps (one duty and one standby) each having a rated capacity of 14.14 L/s at 47 m TDH and an emergency overflow outlet;
- A 150 m diameter forcemain along Booth Street East, Eighth Concession Road and Mapleton WPCP Access Road discharging to the influent structure of the sewage treatment plant;
- A 50 kW outdoor diesel generator set.

Drayton

Sanitary Sewage Collection System (Off-site)

Sanitary sewer on Mill Street, High Street, Smith Drive, Spring Street, Main Street, Wood Street, Robin Drive, John Street, Union Street, Edward Street, Elm Street, Wellington Street, Easement West of Wellington Street, King Street, Queen Street and Wortley Street, Conestoga Drive, Hillview Drive, Pine Street, Maple Street, Green Street, Andrew Drive, Dales Drive, Parkside Street, Andrews Drive West, Faith Drive, River Run Road, Riverview Drive, Bedell Drive Pioneer Drive.

Sewage Pumping Station and Forcemain (Off-site)

- A sewage pumping station located on the north side of Mill Street consists of a wet well approximately 110 m west of the west limit of Wellington Street with a wet well with two (2) sewage pumps (one duty and one standby) each rated at 34.0 L/s at a TDH of 42.0 m;
- A forcemain to the waste stabilization ponds, emergency bypass connection on the discharge forcemain;
- A 60 kW standby diesel generator and emergency station overflow;

Stabilization Pond:

- A 21.2 ha waste stabilization pond system with (2) treatment cells operated in series and three (3) effluent treatment/storage cells operated in parallel or series with individual operating depths (exclusive of sludge storage bottom zones and freeboard), areas and volumes as listed in Table 1:

Table 1.

Parameters	Function	Operating Depth (m)	Surface Area (ha)	Operating Volume (m ³)
Cell 2	Treatment – Primary Cell	1.825	3.1	60,500
Cell 1	Treatment – Secondary Cell	1.825	3.2	62,100
Cell 3	Storage/treatment	2.425	5.5	131,700
Cell 4A	Storage/treatment	2.600	3.4	77,600
Cell 4B	Storage/treatment	2.600	6.0	140,700
		Total	21.2	472,600

- Influent works to Cell #2, interconnecting structures between lagoon cells;
- A primary gravity flow control structure (flow control structure A) with adjustable weir control, receiving influent from Cell #1 and with valved inlet/outlet pipes to Cells #3, 4A and 4B, and outlet pipe to Manhole 2;
- A secondary gravity flow control structure (flow control structure B) with valved inlet/outlet pipes to Cells 4A and 4B and the primary flow control chamber;
- A fine bubble aeration system for Cell #2 comprising two high speed blowers (duty/standby) having a capacity of 680 m³/h at 45 kPa were decommissioned and removed in 2017, and two Positive Displacement Blowers (duty/standby), were installed. Each blower is 30 HP and is equipped with its own VFD's with the existing Positive Displacement Blower as back up. The feeder lines and diffuser tubes at the bottom of the cell are perpendicular to the direction of sewage flow;
- A compressed air distribution system in Cell #3 comprising a 25 hp compressor/blower, air header and distribution laterals for minimizing ice formation and to improve alum mixing;
- Effluent works and 600 mm diameter sewer to the stabilization pond effluent pumping station;

Stabilization Pond Effluent Pumping Station:

- A 3.4 m by 3.3 m by 6.0 m deep wet well, including a bypass/overflow chamber with a bottom sluice gate and an overflow weir, equipped with three (3) submersible pumps (two duty and one shelf spare) with variable speed 3 hp motors, each having a capacity of 23.1 L/second at 4.0 m TDH, with a 150 mm diameter pipe discharging stabilization pond effluent to a common trough at the top of the wet well;
- One (1) 200 mm diameter gravity flow pipe conveying stabilization pond effluent from the trough to the filtration building;
- A 600 mm diameter emergency bypass/overflow sewer from the pumping station to the final effluent manhole;

Supplementary Treatment Systems:

Phosphorus Removal

- A 4.3 m x 6.1 m alum building with a 15,000 L alum storage tank and two (2) 7.1 L/h capacity metering pumps to dose alum to flow control structure A located upstream of the storage lagoons;
- A new alum dosing system with a duplex pump control panel and two (2) metering pumps (duty and standby arrangement), each capable of handling 15L/hr;
- An insulated alum dosing pipe with fittings and other appurtenances;
- Installation of the alum dosing point within the filter feed pumping station wet well;
- Installation of a pipe mixer (static flow mixer) within the existing stainless steel filter feed pipe and necessary connections with fittings to the existing 200 mm diameter stainless steel filter feed pipe.

Supplementary Treatment Systems:

Phosphorus Removal

secondary pre-filtration alum dosing system to facilitate additional phosphorus removal, housed in an alum building, including:

- one (1) 9,000 L alum storage tank;
- an alum dosing system with a duplex pump control panel and two (2) metering pumps (duty and standby arrangement), each capable of handling 15 L/hr;
- an insulated alum dosing pipe with fittings and other appurtenances;
- installation of the alum dosing point within the filter feed pumping station wet well;
- installation of a pipe mixer (static flow mixer) in a precast chamber within the existing stainless steel filter feed pipe and necessary connections with fittings to the existing 200 mm diameter stainless steel filter feed pipe.

Post-Secondary Treatment System:

Sand Filters

- One (1) metering chamber complete with 200 mm diameter inlet pipe from the Stabilization Pond Effluent Pumping Station, a 200 mm diameter magnetic flowmeter and a 200 mm outlet pipe discharging to the filter influent channel described below;
- One (1) filter influent channel 690 mm wide by 2.5 m deep equipped with a stainless steel screen and guide, five (5) 200 mm diameter filter inlet pipes with gate valves and one (1) 200 mm diameter overflow pipe discharging to the filter effluent channel;
- Five (5) continuous backwash upflow sand filters, each having a 4.65 m² filtration area, 2.0 m depth coarse media, with design filtering capacity of 800 m³/day, complete with headloss gauges, air-lift pumps for rejection/backwashing of filters to the reject wet well and effluent weirs;
- A 250 mm diameter filtered effluent pipe and a 500 mm wide by 1.6 m deep effluent channel for the disinfection system described below;
- Two (2) air compressors with 7.5 hp motors, each having an output capacity of 46 m³/h at 690 kPa pressure discharging to a common air reservoir to provide air to the air lift pumps;
- A 2.16 m by 1.7 m, 4.7 m deep reject/backwash wastewater wet well equipped with two (2) submersible pumps with 3 hp integral motors (one duty and one standby), each having a capacity of 13.5 L/s at 10.7 m TDH, to pump filter reject/backwash wastewater to Cell #2 of the stabilization pond system via an approximately 37.0 m long 100 mm diameter forcemain;

Disinfection System:

UV Disinfection

Two (2) ultraviolet radiation units installed in series in the effluent channel of the filtration building, designed to handle a peak flow of 4,000 m³/d and capable of producing a minimum dose of

36 mW.sec/cm² in the effluent with an ultraviolet transmittance of 65%, for the disinfection of effluent;

Final Effluent Flow Measurement and Sampling Point:

- One (1) 200 mm dia magnetic flowmeter and associated pipework in the effluent discharge system.

Final Effluent Disposal Facilities:

- A reinforced concrete cascade aerator including a 100 mm diameter drain/bypass pipe to provide adequate aeration to the filtered effluent prior to discharging to the Conestogo River,
- One (1) 300 mm diameter effluent discharge pipe from the cascade aerator to the final effluent manhole;
- One (1) 600 mm diameter final effluent pipe to the outfall structure at the Conestogo River

An overview of Mapleton Wastewater Pollution Control Plant can be found in Table 2:

Table 2. Mapleton Wastewater Pollution Control Plant Overview

Facility Name	Mapleton Wastewater Pollution Control Plant
Facility Type	Facultative Lagoons, Aerated Lagoon (Cell #2), Alum addition/phosphorous removal, sand filters, sewer system and UV Disinfection, and two pumping stations.
Plant Classification	WWT I
Works Number	120001782
Design Capacity	900 m ³ /day
Receiving Water	Conestogo River
Environmental Compliance Approval	ECA# 1391-B38PLA - August 2, 2018

2. Influent and Effluent Monitoring and Comparison to Effluent Objectives and Effluent Limits

2.1 Influent (Raw Sewage)

As per Section 11(4)(a) of ECA 1391-B38PLA, a summary and interpretation of all Influent monitoring data, and a review of the historical trend of the sewage characteristics and flow rates is required.

2.1.1 Sampling Frequency: Influent

Samples of raw sewage (influent) are collected and analyzed on a regular basis. The sampling types and frequencies are summarized in Table 3. The sampling frequencies meet the requirements set out in Schedule D of ECA 1391-B38PLA.

Table 3. Raw Sewage Monitoring – Sampling Frequencies

Parameter	Sample Type	Frequency
BOD ₅ *	Grab	Bi-Weekly
Total Suspended Solids*	Grab	Bi-Weekly
Total Phosphorous*	Grab	Bi-Weekly
Total Kjeldahl Nitrogen*	Grab	Bi-Weekly

*Refer to Appendix A for monthly sample results.

2.1.2 Influent (Raw Sewage) Monitoring Data

The following parameters in Table 4 do not have limits or objectives but are monitored on a regular basis (see Section 2.1.1 for sampling frequency) as required by Schedule D of ECA 1391-B38PLA. Table 4 summarizes the influent monitoring data for the reporting period.

Table 4. Raw Sewage Monitoring Parameters as required by ECA 1391-B38PLA for Mapleton Wastewater Pollution Control Plant, 2021

Parameter	Average	Minimum	Maximum
BOD ₅ * (mg/L)	299.74	168.50	426.50
Total Suspended Solids* (mg/L)	290.18	139.50	413.00
Total Phosphorous* (mg/L)	7.12	5.76	10.56
Total Kjeldahl Nitrogen* (mg/L)	60.53	46.70	76.05


*Refer to Appendix A for monthly sample results.

2.1.3 Historical Trends of Influent (Sewage) Characteristics and Influent Flowrates

Sewage Characteristics


The below graph shows historical raw Biochemical Oxygen Demand (BOD₅) trending from 2017 to 2021. A review of the trends from the last 5 years for BOD₅ shows that the average BOD₅ concentration in the raw sewage had fluctuated year per year. A continued decrease in BOD₅ loading was observed in 2021 comparatively to previous years.

Figure 1.




The below graph shows the historical raw Total Suspended Solids trending from 2017 to 2021. A review of the current 2021 trends versus the last 5 years has shown a slight increase in loadings of Total Suspended Solids for the parts of the year.

Figure 2.




The below graph shows the historical raw Total Phosphorus trending from 2017 to 2021. A review of the current 2021 trends versus the last 5 years has shown a slight increase in loadings of phosphorus for the parts of the year.

Figure 3.



The below graph shows the historical raw Total Kjeldahl Nitrogen trending from 2017 to 2021. A review of the 2021 trends versus the last 5 years for TKN has shown a slight increase in loadings concentrations to previous years.


Figure 4.



Influent Flow:

The below graph shows historical raw flow trending from 2017 to 2021. The graph shows that the average flows have remained fairly consistent. There is a consistent peak in the months of March-April which would represent warmer temperatures resulting in snow melt and seasonal precipitation.

Figure 5.



The total raw sewage volume of wastewater treated in 2021 was 233,343.00 m³. The annual average daily flow of raw sewage was 638.84 m³/day was 70.98 % of the rated capacity (900 m³/day). The maximum peak flow of 2,008.00 m³/day occurred in March due to higher seasonal temperatures which resulted in rapid snow melt as well as heavy rainfall. This represents a peak flow of 2.23 times the rated capacity.

2.2 Final Effluent Monitoring and Flow Rates

As per Section 11(4)(b) of ECA 1391-B38PLA, a summary and interpretation of all Final Effluent monitoring data, including concentration, flow rates, loading and a comparison to the designed objectives and compliance limits in this approval, including an overview of the success and adequacy of the Works is required.

2.2.1 Sampling Frequency: Effluent

Samples of effluent are collected and analyzed on a regular basis. The sampling types and frequencies are summarized in Table 5. The sampling frequencies meet the requirements set out in Schedule C of ECA 1391-B38PLA.

Table 5. Effluent Sampling Monitoring – Sampling Frequencies

Parameters	Sample Type	Frequency
CBOD ₅ *	24-hour Composite	Weekly
Total Suspended Solids*	24-hour Composite	Weekly
Total Phosphorous*	24-hour Composite	Weekly
Total Ammonia Nitrogen*	24-hour Composite	Weekly
E. Coli*	Grab	Weekly
pH	Grab/Probe	Weekly
Temperature	Grab/Probe	Weekly
Unionized Ammonia	Calculated	Weekly

*Refer to Appendix A for monthly sample results.

2.2.2 Effluent Monitoring Data

Table 6. Effluent Monitoring Parameters as required by ECA 1391-B38PLA for Mapleton Wastewater Pollution Control Plant, 2021

Parameters	Average	Minimum	Maximum	Average Annual Loading
CBOD ₅	2.30	2.00	3.00	6.21
Total Suspended Solids	4.05	2.00	5.00	10.66
Total Phosphorus	0.106	0.055	0.155	0.279
Total Ammonia Nitrogen	0.143	0.100	0.267	0.380
E.Coli	2.69	1.59	5.85	-
pH	8.11	7.99	8.26	-
Temperature	7.32	0.80	16.50	-
Unionized Ammonia	0.005	0.001	0.016	-

*Refer to Appendix A for monthly sample results.

2.2.3 Effluent Objectives and Limits

The effluent objectives as per Schedule B of ECA 1391-B38PLA for the Mapleton Wastewater Pollution Control Plant are:

Table 7. Effluent Objectives as per Schedule B of ECA 1391-B38PLA

Effluent Parameter	Concentration Objective (mg/L)
CBOD ₅	5.0
Total Suspended Solids	15.0
Total Ammonia Nitrogen	3.0
Total Phosphorous	0.25
E.Coli	100 CFU/100mL (Monthly Geometric Mean Density)
pH	6.5-8.5 inclusive

The effluent limits that are to be met as per Schedule C of ECA 1391-B38PLA for the Mapleton Wastewater Pollution Control Plant are found in Table 8. Any exceedance with the limits found in Table 8 constitutes a non-compliance.

Table 8. Effluent Limits as per Schedule C of ECA 1391-B38PLA

Effluent Parameter	Concentration Limit (mg/L)
CBOD ₅ (April, October)	7.5
(March, November, December)	10.0
Total Suspended Solids	25.0
Total Ammonia Nitrogen	5.0
Total Phosphorous	0.42
E.Coli	200 CFU/100mL (Monthly Geometric Mean Density)
pH	6.0-9.5 Inclusive

2.2.4 Comparison of Data to Effluent Objectives and Effluent Limits

Analytical and monitoring data for the Mapleton Wastewater Pollution Control Plan is stored in OCWAs data management system (WISKI). Annual and monthly averages for flows, CBOD₅, Total Suspended Solids, Total Phosphorous, Nitrogen-series and E.coli can be found in Appendix A. A comparison of analytical data from effluent samples to the effluent objectives and effluent limits shown in the below tables:

Concentrations and Loading

Table 9.

	CBOD ₅			
	Monthly Average Concentration (mg/L)	Within Objectives (5.00 mg/L)	Within Limits (7.50 mg/L Apr., Oct) (10.00 mg/L Mar.,Nov.,Dec.)	Monthly Average Loading (kg/d)
January	-	-	-	-
February	-	-	-	-
March	2.00	Yes	Yes	5.53
April	2.00	Yes	Yes	5.11
May	-	-	-	-
June	-	-	-	-
July	-	-	-	-
August	-	-	-	-
September	-	-	-	-
October	3.00	Yes	Yes	9.37
November	2.50	Yes	Yes	6.66
December	2.00	Yes	Yes	4.40

Table 10.

	Total Suspended Solids			
	Monthly Average Concentration (mg/L)	Within Objectives (15.00 mg/L)	Within Limits (25.00 mg/L)	Monthly Average Loading (kg/d)
January	-	-	-	-
February	-	-	-	-
March	2.00	Yes	Yes	5.53
April	4.50	Yes	Yes	11.49
May	-	-	-	-
June	-	-	-	-
July	-	-	-	-
August	-	-	-	-
September	-	-	-	-
October	4.25	Yes	Yes	13.28
November	4.50	Yes	Yes	11.99
December	5.00	Yes	Yes	11.00

Table 11.

	Total Phosphorus			
	Monthly Average Concentration (mg/L)	Within Objectives (0.25 mg/L)	Within Limits (0.42 mg/L)	Monthly Average Loading (kg/d)
January	-	-	-	-
February	-	-	-	-
March	0.08	Yes	Yes	0.22
April	0.06	Yes	Yes	0.14
May	-	-	-	-
June	-	-	-	-
July	-	-	-	-
August	-	-	-	-
September	-	-	-	-
October	0.13	Yes	Yes	0.40
November	0.11	Yes	Yes	0.29
December	0.16	Yes	Yes	0.34

Table 12.

	Total Ammonia Nitrogen (Ammonia Nitrogen + Ammonium Nitrogen)			
	Monthly Average Concentration (mg/L)	Within Objectives (3.0 mg/L)	Within Limits (5.0 mg/L)	Monthly Average Loading (kg/d)
January	-	-	-	-
February	-	-	-	-
March	0.27	Yes	Yes	0.74
April	0.10	Yes	Yes	0.26
May	-	-	-	-
June	-	-	-	-
July	-	-	-	-
August	-	-	-	-
September	-	-	-	-
October	0.10	Yes	Yes	0.31
November	0.10	Yes	Yes	0.27
December	0.15	Yes	Yes	0.33

Table 13.

	E.coli		
	Monthly Geometric Mean Density (CFU/100mL)	Within Objectives (100 CFU/100mL)	Within Limits (200 CFU/100mL)
January	-	-	-
February	-	-	-
March	1.59	Yes	Yes
April	2.00	Yes	Yes
May	-	-	-
June	-	-	-
July	-	-	-
August	-	-	-
September	-	-	-
October	2.00	Yes	Yes
November	5.85	Yes	Yes
December	2.00	Yes	Yes


Table 14.

	pH			
	Minimum	Maximum	Within Objectives (6.5 – 8.5)	Within Limits (6.0 – 9.5)
January	-	-	-	-
February	-	-	-	-
March	8.10	8.16	Yes	Yes
April	7.99	8.16	Yes	Yes
May	-	-	-	-
June	-	-	-	-
July	-	-	-	-
August	-	-	-	-
September	-	-	-	-
October	8.00	8.24	Yes	Yes
November	8.02	8.26	Yes	Yes
December	8.12	8.14	Yes	Yes

2.2.5 Final Effluent Flow and Maximum Discharge Rates

Effluent Flow: The below graph shows historical final effluent flow trending from 2017 to 2021. The graph shows that during the discharge periods the final effluent average flows have remained fairly consistent between the discharge periods.

Figure 6.



The total effluent volume of wastewater treated in 2021 was 274,535.43 m³ with an annual average daily flow of effluent was 2,660.82 m³/day. See table 15 for comparison of maximum daily effluent flow to the maximum final effluent discharge rates as per Schedule C.

Table 15.

2022	Monthly Average Daily Effluent Flow	Monthly Average Daily Effluent Flow Limit
	(m ³)	(m ³ /day)
March	2,763.47	2,599
April	2,552.84	4,000
October	3,123.54	233
November	2,664.71	1,854
December	2,199.56	4,000

*As per section Section 8(5) The Owner shall operate the Works such that discharge of Final Effluent from the Works is conducted on a seasonal discharge basis with the effluent being discharged only during the months at the rates as specified in Schedule C. However, discharges in excess of these daily discharges is allowed if the minimum 10:1 of the streamflow to daily discharge rate for the applicable period of that design streamflow occurs, based on actual measurements of flow rate in the Conestogo River.

2.5 Overview of Success and Adequacy of the Works;

The annual average effluent TSS concentration was 4.05 mg/L with a removal efficiency of >98.32%. The annual average effluent Total Phosphorus concentration was 0.106 mg/L with a removal efficiency of >97.52%.

The bacteriological quality of the effluent complied with the environmental compliance approval requirement of <200 colony forming units per 100 mL sample. The annual geometric mean density of organisms for 2021 was 2.69 per 100 mL, indicating extremely effective effluent disinfection.

3. Deviation from the Monitoring Schedule

As per Section 11(4)(c) of ECA 1391-B38PLA, a summary of any deviation from the monitoring schedule and reasons for the current reporting year and a schedule for the next reporting year is required.

Table 16.

Date	Reason for Deviation
August 20, 2021	Raw sample taken 1 day later than scheduled – Delayed due to operational issues
September 3, 2021	Raw sample taken 1 day later than scheduled - Delayed due to operational issues
September 29, 2021	Raw sample taken 1 day earlier than scheduled – Due to scheduled contract work
December 22, 2021	Raw sample taken 1 day earlier than scheduled due to Stat Holidays/Lab closures

Refer to Appendix B the schedule for the next reporting year (2022).

4. Operating Problems and Corrective Actions

As per Section 11(4)(d) of ECA 1391-B38PLA, a summary of all operating issues encountered and corrective actions taken is required.

There were no operating problems encountered or corrective actions required at the Mapleton Wastewater Pollution Control Plant during 2021 that affected the quality of the effluent leaving the plant. All repairs/maintenance can be found in Section 5 of this report.

5. Major Maintenance Activities

As per Section 11(4)(e) of ECA 1391-B38PLA, a summary of all normal and emergency repairs and maintenance activities carried out on any major structure, equipment, apparatus or mechanism forming parts of the Works is required.

For 2021, major maintenance activities that occurred include:

- Air Compressor annual inspection/maintenance
- Pumps and MCC Panel inspections
- Generator inspection
- Replaced faulty air lift on sand filter
- Annual wet well pumps/influent pumps maintenance
- Flow Meter calibrations
- Wet Well cleanout
- Check valve balls replaced at Drayton Sewage PS
- Sewage Pump #2 repairs
- Drayton PS forceman weld repair
- Flushing and CCTV in collection system
- Air relief emergency repair
- 2 valves repaired in mixing chamber

Plant maintenance, including non-scheduled maintenance is monitored using Maximo Workplace Management System. All routine and preventative maintenance was conducted as scheduled in 2021.

6. Effluent Quality Assurance and Control

As per Section 11(4)(f) of ECA 1391-B38PLA, *a summary of any effluent quality assurance or control measures undertaken* is required:

All laboratory analyzed raw sewage and effluent samples (Section 2.1.1 and Section 2.2.1) are analyzed by SGS Canada Inc., which is an ISO 17025 accredited laboratory. In-house tests are conducted for monitoring purposes by licensed operators using standardized methods. The results from in-house tests are used to determine treatment efficiency and to effectively maintain process control. Calibrations and preventative maintenance are performed on facility equipment and monitoring equipment, see Section 5 for more details. In addition to sample analysis, preventative maintenance is scheduled for equipment at the sewage treatment plant and pumping stations at regular frequency (frequency depends on the equipment and type of maintenance). Maintenance activities are scheduled in the work management system Maximo.

Operation by Licensed Operators: This sewage system is operated and maintained by the OCWA's licensed staff. The mandatory licensing program for operators of sewage treatment facilities in Ontario is regulated under the Ontario Water Resources Act (OWRA) Ontario Regulation 129/04. Licensing means that an individual meets the education and experience requirements and has successfully passed the certification exam.

The following are licensed operators who operated this facility during 2021 with current license classification, license numbers and license expiry dates.

7. Calibration and Maintenance Procedures

As per Section 11(4)(g) of ECA 1391-B38PLA, *a summary of the calibration and maintenance carried out on all Influent and Final Effluent monitoring equipment to ensure that the accuracy is within the tolerance of that equipment as required in this Approval or recommended by the manufacturer* is required.

All in-house monitoring equipment is calibrated/verified as per manufacturer's recommendations. Monitoring and metering equipment is also calibrated by a third party on an annual basis. Preventative maintenance is scheduled for all equipment at the sewage treatment plant and pumping stations at regular frequency (frequency depends on the equipment and type of maintenance). Maintenance

activities are scheduled within the work management system Maximo, upon completion, Operators set the work order to complete. On a monthly basis, preventative work orders are reviewed for completion.

Indus Controls was contracted to calibrate flow measuring equipment on September 13, 2021. Copies of these calibration reports can be found in Appendix C of this report.

8. Efforts and Results Achieved in Meeting Effluent Objectives

As per Section 11(4)(h) of ECA 1391-B38PLA, *a summary of efforts made to achieve the design objectives in this Approval, including an assessment of the issues and recommendations for pro-active actions if any are required under the following situation:*

- i. When any of the design objectives is not achieved more than 50% of the time in a year, or there is an increasing trend in deterioration of Final Effluent quality;*

The Mapleton WWTP was able to achieve final effluent parameter design objectives (refer to Table 7) 100% of the time in the year. The CBOD₅, TSS, TP, TAN, E.Coli and pH were within the Effluent Limits 100% of the time during the reporting period. Based on the data, the final effluent was within the Effluent Objectives the majority of the time and there appears to be no increased trend in deterioration of final effluent quality.

During the reporting period, operations staff regularly completed visual inspections of final effluent samples and found the effluent to be essentially free of floating and settleable solids. The final effluent did not appear to contain oil and no visible film, sheen, foam or discoloration were observed.

- ii. When the Annual Average Daily Influent Flow reaches 80% of the Rated Capacity;*

During the reporting period the annual average daily influent flow did not exceed 80% of the rated capacity. The annual average daily flow of raw sewage in 2021 was 70.98 % (638.84 m³/day) of the rated capacity (900 m³/day). As this Average Daily Influent Flow is approaching 80% of the Rated Capacity, the Owner of the system was made aware of the increased capacity required in the future. Currently, capacity upgrades are being investigated.

Condition 6 is imposed “to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs and before the compliances limits of Condition 6 are exceeded.”

OCWA as the Operating Authority (on behalf of the Owner) has made best efforts to stay within the Effluent Objectives in the ECA. These efforts are supported through:

- Continuous monitoring equipment
- Regular plant inspections/checks
- In-house sampling and testing
- Laboratory (3rd party) analysis of influent and effluent samples
- Data review
- Process optimization and adjustments (as required)
- Scheduled/preventative maintenance
- Repairs as necessary

A summary of the effluent quality in comparison to the effluent objectives can be found in Tables 9-13. These results show that sewage treatment operations for 2021 provided effluent quality that was within all effluent objectives outlined in the ECA and minimized environmental impairment.

9. Sludge Generation

As per Section 11(4)(i) of ECA 1391-B38PLA, *an estimate of sludge volumes in the lagoon cells. Sludge volume is to be measured every five (5) years, but may be estimated in the interim years. A summary of disposal locations and volumes of sludge disposed of must also be provided if sludge was disposed of during the reporting period* is required

There was no sludge hauled from the lagoon system in 2021. Currently, the volume of sludge in Cell #1 is being investigated for removal and haulage. It is proposed to be cleaned out during the late Summer of 2022.

The estimate sludge volume in the lagoon cells

Table 17.

Cell	Estimated Sludge Volume (m ³)
Cell 1	800
Cell 2	500
Cell 3	220
Cell 4A	125
Cell 4B	100

10. Complaints

As per Section 11(4)(j) of ECA 1391-B38PLA, *a summary of any complaints received during the reporting period and any steps taken to address the complaints* is required.

A standard operating procedure (SOP) is in place for addressing complaints received from the community. All complaints are addressed and documented in the facility logbook. Community complaint information is entered in OCWA's electronic database system "WMS Maximo". This system contains all the required information and history of all complaints.

There were no complaint registered in 2021 for the reporting period.

11. By-pass, Spill or Abnormal Discharge Events

As per Section 11(4)(k) of ECA 1391-B38PLA, *a summary of all By-pass, Overflows, other situations outside Normal Operating Conditions and spills within the meaning of Part X of EPA and abnormal discharge events* is required.

One spill event occurred during the 2021 reporting period. On June 15, 2021 a rotted air relief valve within a manhole located between the driveways of the farmer and the lagoon access caused raw sewage to collect in the manhole and spill. Please refer to Appendix D for Environmental Incident Report and Notifications.

12. Notice of Modifications

As per Section 11(4)(l) of ECA 1391-B38PLA, *a summary of all Notice of Modifications to Sewage Works completed under Paragraph 1.d. of Condition 10, including a report on status of implementation of all modification* is required.

There were no modifications made during the reporting period to the Mapleton Wastewater Pollution Control Plant which would require a Notice of Modifications be submitted to the Water Supervisor.

13. Bypass/Overflow Proposed Elimination Projects

As per Section 11(4)(m) of ECA 1391-B38PLA, *a summary of efforts made to achieve conformance with Procedure F-5-1 including but not limited to projects undertaken and completed in the sanitary sewer systems that result in overall Bypass/Overflow elimination including expenditures and proposed projects to eliminate Bypass/Overflows with estimated budget forecast for the year following that for which the report is submitted* is required.

The Mapleton Wastewater Pollution Control Plant has not had bypass/overflow occurrences during this reporting period. Therefore this doesn't propose any future occurrences which don't require a project/expenditure to eliminate bypass/overflows.

14. Changes/updates to Scheduled Construction/Commissioning

As per Section 11(4)(n) of ECA 1391-B38PLA, *any changes or updates to the schedule for the completion of construction and commissioning operation of major process(es)/equipment groups in the Proposed Works* is required.

The Proposed Works reached substantial completion as of November 15, 2018.

**2021 Annual Performance Report
Mapleton Water Pollution Control Plant
ECA# 1391-B38PLA August 2, 2018**

Appendix A

Performance Assessment Report

2021

Ontario Clean Water Agency
 Performance Assessment Report Wastewater/Lagoon

From: 01/01/2021 to 31/12/2021

Report extracted 02/07/2022 12:35

Facility: [6093] DRAYTON WASTEWATER TREATMENT LAGOON

Works: [120001782]

	01/2021	02/2021	03/2021	04/2021	05/2021	06/2021	07/2021	08/2021	09/2021	10/2021	11/2021	12/2021	<-Total-->	<-Avg-->	<-Max-->	<-Criteria-->
Flows:																
Raw Flow: Total - Raw Sewage Drayton (m³)	16109.00	13261.00	24152.00	18654.00	14497.00	14792.00	13762.00	13512.00	19613.00	17947.00	17757.00	22068.00	206124.00			
Raw Flow: Total - Raw Sewage Flow from Moorefield (m³)	2276.00	2131.00	2829.00	2195.00	2129.00	1977.00	2064.00	2194.00	2334.00	2243.00	2347.00	2500.00	27219.00			
Raw Flow: Avg - Raw Sewage Drayton (m³/d)	519.65	473.61	779.10	621.80	467.65	493.07	443.94	435.87	653.77	578.94	591.90	711.87			564.26	750.0
Raw Flow: Avg - Raw Sewage Flow from Moorefield (m³/d)	73.42	76.11	91.26	73.17	68.68	65.90	66.58	70.77	77.80	72.35	78.23	80.65			74.58	
Raw Flow: Max - Raw Sewage Drayton (m³/d)	729.00	861.00	1872.00	1631.00	683.00	1282.00	654.00	697.00	1833.00	1125.00	796.00	1507.00			1872.00	
Raw Flow: Max - Raw Sewage Flow from Moorefield (m³/d)	117.00	122.00	151.00	93.00	94.00	103.00	86.00	96.00	152.00	112.00	104.00	143.00			152.00	
Eff. Flow: Total - Final Effluent (m³)			66323.20	25528.84						81212.09	77276.56	24195.18	274535.43			
Eff. Flow: Avg - Final Effluent (m³/d)			2763.47	2552.84						3383.84	3223.88	1003.19			2660.82	1581.0 - 3154.0 - 233.0 - 1754.0 - 4000.0
Eff. Flow: Max - Final Effluent (m³/d)			3572.20	3286.60						3375.28	3033.80	2491.89			3572.20	
Raw Flow: Monthly Total - Raw Sewage Total (m³)	18385.00	15392.00	28981.00	20849.00	16626.00	16769.00	15826.00	15706.00	21947.00	20190.00	20104.00	24568.00	233343.00			
Raw Flow: Monthly Avg - Raw Sewage Total (m³/d)	593.06	549.71	870.35	694.97	536.32	558.97	510.52	506.65	731.57	651.29	670.13	792.52			638.84	
Raw Flow: Monthly Max - Raw Sewage Total (m³/d)	836.00	965.00	2008.00	1697.00	756.00	1385.00	728.00	781.00	1978.00	1225.00	877.00	1650.00			2008.00	
Carbonaceous Biochemical Oxygen Demand: CBOD:																
Eff: Avg cBOD5 - Final Effluent (mg/L)			< 2.000	< 2.000						3.000	< 2.500	< 2.000		< 2.300	3.000	0 - 7.5 - 7.5 - 10.0 - 10.0
Eff: # of samples of cBOD5 - Final Effluent (mg/L)			3	2						4	4	2	15			
Loading: cBOD5 - Final Effluent (kg/d)			< 5.527	< 5.106						9.371	< 6.662	< 4.399		< 6.213	9.371	
Biochemical Oxygen Demand: BOD5:																
Raw: Avg BOD5 - Raw Sewage Drayton (mg/L)	426.500	168.500	412.000	285.333	319.500	220.000	325.500	400.000	253.000	227.500	269.500	289.500	299.736	426.500		
Raw: # of samples of BOD5 - Raw Sewage Drayton (mg/L)	2	2	2	3	2	3	2	2	3	2	2	2	27			
Total Suspended Solids: TSS:																
Raw: Avg TSS - Raw Sewage Drayton (mg/L)	355.000	139.500	380.000	268.000	326.000	176.000	253.500	413.000	256.667	269.500	305.000	340.000	290.181	413.000		
Raw: # of samples of TSS - Raw Sewage Drayton (mg/L)	2	2	2	3	2	3	2	2	3	2	2	2	27			
Eff: Avg TSS - Final Effluent (mg/L)			< 2.000	4.500						4.250	< 4.500	5.000		< 4.050	5.000	
Eff: # of samples of TSS - Final Effluent (mg/L)			3	2						4	4	2	15			
Loading: TSS - Final Effluent (kg/d)			< 5.527	11.488						13.275	< 11.991	10.998		< 10.656	13.275	
Percent Removal: TSS - Final Effluent (mg/L)			99.474	98.321						98.423	98.525	98.529			99.474	
Total Phosphorus: TP:																
Raw: Avg TP - Raw Sewage Drayton (mg/L)	7.405	5.760	6.055	6.647	7.565	6.973	10.560	8.450	6.343	7.090	6.395	6.250	7.124	10.560		
Raw: # of samples of TP - Raw Sewage Drayton (mg/L)	2	2	2	3	2	3	2	2	3	2	2	2	27			
Eff: Avg TP - Final Effluent (mg/L)			0.080	0.055						0.128	0.110	0.155	0.106	0.155	0.5	
Eff: # of samples of TP - Final Effluent (mg/L)			3	2						4	4	2	15			
Loading: TP - Final Effluent (kg/d)			0.221	0.140						0.398	0.293	0.341	0.279	0.398		
Percent Removal: TP - Final Effluent (mg/L)			98.679	99.173						98.202	98.280	97.520			99.173	
Nitrogen Series:																
Raw: Avg TKN - Raw Sewage Drayton (mg/L)	60.450	46.700	48.750	59.700	63.050	59.700	76.050	74.050	57.133	69.700	55.300	55.750	60.528	76.050		
Raw: # of samples of TKN - Raw Sewage Drayton (mg/L)	2	2	2	3	2	3	2	2	3	2	2	2	27			
Eff: Avg TAN - Final Effluent (mg/L)			< 0.267	< 0.100						< 0.100	< 0.100	0.150	< 0.143	0.267	5.0	
Eff: # of samples of TAN - Final Effluent (mg/L)			3	2						4	4	2	15			
Loading: TAN - Final Effluent (kg/d)			< 0.737	< 0.255						< 0.312	< 0.266	0.330	< 0.380	0.737		
Disinfection:																
Eff: GMD E. Coli - Final Effluent (cfu/100mL)			1.587	2.000						2.000	5.846	2.000	2.687	5.846		
Eff: # of samples of E. Coli - Final Effluent (cfu/100mL)			3	2						4	4	2	15			

**2021 Annual Performance Report
Mapleton Water Pollution Control Plant
ECA# 1391-B38PLA August 2, 2018**

Appendix B

2022 Sampling Schedule

2021

2022 Drayton Lagoons Sampling Schedule

JANUARY						
S	M	T	W	T	F	S
						1
2	3	4	5	6	7	8
9	10	11	12	13	14	15
16	17	18	19	20	21	22
23	24	25	26	27	28	29
30	31					

FEBRUARY						
S	M	T	W	T	F	S
		1	2	3	4	5
6	7	8	9	10	11	12
13	14	15	16	17	18	19
20	21	22	23	24	25	26
27	28					

MARCH						
S	M	T	W	T	F	S
		1	2	3	4	5
6	7	8	9	10	11	12
13	14	15	16	17	18	19
20	21	22	23	24	25	26
27	28	29	30	31		

APRIL						
S	M	T	W	T	F	S
					1	2
3	4	5	6	7	8	9
10	11	12	13	14	15	16
17	18	19	20	21	22	23
24	25	26	27	28	29	30

MAY						
S	M	T	W	T	F	S
1	2	3	4	5	6	7
8	9	10	11	12	13	14
15	16	17	18	19	20	21
22	23	24	25	26	27	28
29	30	31				

JUNE						
S	M	T	W	T	F	S
			1	2	3	4
5	6	7	8	9	10	11
12	13	14	15	16	17	18
19	20	21	22	23	24	25
26	27	28	29	30		

JULY						
S	M	T	W	T	F	S
					1	2
3	4	5	6	7	8	9
10	11	12	13	14	15	16
17	18	19	20	21	22	23
24	25	26	27	28	29	30
31						

AUGUST						
S	M	T	W	T	F	S
	1	2	3	4	5	6
7	8	9	10	11	12	13
14	15	16	17	18	19	20
21	22	23	24	25	26	27
28	29	30	31			

SEPTEMBER						
S	M	T	W	T	F	S
				1	2	3
4	5	6	7	8	9	10
11	12	13	14	15	16	17
18	19	20	21	22	23	24
25	26	27	28	29	30	

OCTOBER						
S	M	T	W	T	F	S
						1
2	3	4	5	6	7	8
9	10	11	12	13	14	15
16	17	18	19	20	21	22
23	24	25	26	27	28	29
30	31					

NOVEMBER						
S	M	T	W	T	F	S
		1	2	3	4	5
6	7	8	9	10	11	12
13	14	15	16	17	18	19
20	21	22	23	24	25	26
27	28	29	30			

DECEMBER						
S	M	T	W	T	F	S
				1	2	3
4	5	6	7	8	9	10
11	12	13	14	15	16	17
18	19	20	21	22	23	24
25	26	27	28	29	30	31

- Weekly Effluent CBOD5, TSS, TP, TAN, *E. Coli*, pH, Temperature, and Uniozed Ammonia
- Weekly Conestogo River Monitoring BOD5, TSS, TP, TAN, *E. Coli*, pH, and Temperature
- Bi-weekly Influent BOD5, TSS, TP, and TKN + River & Effluent Sampling
- Bi-weekly Influent BOD5, TSS, TP, and TKN
- Lagoon Cell Sampling CBOD5, TSS, TP, TAN, *E. Coli*, pH (see below)

At least seven (7) days prior to a discharge period, sample each Lagoon Cell
 Cell Sampling dates subject to change, red box is a warning to ensure sampling completion prior
 Notes: pH & Temperature of the Final Effluent shall be determined in the field at the
 time of sampling for TAN.

**2021 Annual Performance Report
Mapleton Water Pollution Control Plant
ECA# 1391-B38PLA August 2, 2018**

Appendix C

Calibration Reports

2021



IndusControl Inc.
151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.

VERIFICATION REPORT - ROSEMOUNT ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region
Plant Name: Drayton Lagoon

Site/Plant Address: 7101 Side Road 15,
Drayton, ON, N0G 1P0

Device Information
Make: Rosemount
Model: 8712D
Order Code: NA
Serial No.: 8602203395
Tag: NA
Job Location: Lagoon Flow
Asset ID: NA

Service Information
Date: September 13, 2021
Report No: CO1264-2108-45
Job No: CO1264-2108

Sensor Details
Line size: 8"
Flow Cal Tube No.: 0979205909737005
Mounting: Remote

Flow Details
Unit: l/sec
Flow Range: 0-500 (m3/day)
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 25500

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	2255268	2255269
FLOW (m3/day)	0	0

Maintenance Checklist	Remarks
Visual Inspection: <input checked="" type="checkbox"/> OK <input type="checkbox"/> NOT OK	
Electrical Inspection: <input checked="" type="checkbox"/> OK <input type="checkbox"/> NOT OK	
Sensor Installation: <input checked="" type="checkbox"/> OK <input type="checkbox"/> NOT OK	
Transmitter Installation: <input checked="" type="checkbox"/> OK <input type="checkbox"/> NOT OK	


Instrument Test Information and Results					
Test-Point as Per Calibration KIT	Calculated Flow (FPS)	Calculated O/P (mA)	UUT Display (FPS)	UUT Measured Output (mA)	Deviation (FPS)
0.00	0.00	4.00	0.01	3.99	-0.01
3.00	3.00	5.60	3.01	5.57	-0.01
10.00	10.00	9.33	9.98	9.30	0.02
30.00	30.00	20.00	29.97	19.97	0.03

Information of Tools used for Verification of the Instruments			
Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Rosemount	Fluke	N/A
Model No:	8714D	179	N/A

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Tushar Patel Stamp/Signature 
Printed Date: September 13, 2021



IndusControl Inc.
151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.

VERIFICATION REPORT- MULTIRANGER 200 OPEN CHANNEL FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region
Plant Name: Drayton Lagoon

Site/Plant Address: 7101 Side Road 15,
Drayton, ON, N0G 1P0

Device Information
Make: Milltronics
Model: Multiranger 200
Order Code: N/A
Serial No.: PBD/BN210450
Tag: NA
Job Location: Lagoon

Service Information
Date: September 13, 2021
Report No: CO1264-2108-46
Job No: CO1264-2108

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	974205.19	974216.00

Flow Details
Unit: m3/hr
Flow Range: 0-1382
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 1382

Maintenance Checklist			Remarks
Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK	
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK	

Programming Parameter of Instrument					
Parameter	Discription	Value	Parameter	Discription	Value
P001	Operation	6.00000	P601	Flow Exponent	1.55
P002	Material	1.000	P602	PMD Dimension	0
P004	Transducer	XPS-10	P603	Maximum Head	0.168 m
P005	Units	1	P604	Maximum Flow	1382
P006	Empty	0.952 m	P605	Zero Head	0.00
P007	Span	0.225 m	P608	Flow rate Units	3.00
P620	Low Flow cutoff	0.075m	P210	4mA Setpoint	0.00
P600	Primary Mea. Device	7	P211	20mA Setpoint	1382.00

Instrument Test Information and Results					
Input (%)	Calculated Flow(m3/hr)	Calculated Input (mA)	Flow on Scada (m3/hr)	UUT Measured Output (mA)	Deviation (m3/hr)
0	0.00	4.00	0.34	4.00	0.34
25	345.50	8.00	343.68	7.93	-1.82
50	691.00	12.00	689.99	11.99	-1.01
75	1036.50	16.00	1035.89	16.01	-0.61
100	1382.00	20.00	1381.75	19.99	-0.25

Information of Tools used for Verification of the Instruments		
Device Description:	Manufacturer	Model
Electrical Multimeter	Fluke	179

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Program parameters verified. Measurement works as per specification.

Service Technician : Tushar Patel Stamp/Signature 
Printed Date: September 13, 2021

Flowmeter Verification Certificate Transmitter

Georgian Highlands Region

Drayton-Lagoon

Customer

Plant

Order code

PROMAG 53 W DN200

Tag Name

1.0526 - 1.0526

Device type

L81D5519000

K-Factor

4

Serial number

V2.03.00

Zero point

V1.06.00

Software Version Transmitter

13.09.2021

Software Version I/O-Module

13:36

Verification date

Verification time

Verification result Transmitter: Passed

Test item	Result	Applied Limits
Amplifier	Passed	Basis: 0.55 %
Current Output 1	Passed	0.05 mA
Pulse Output 1	Not tested	0 P
Test Sensor	Passed	

FieldCheck Details

551063

Production number

1.07.10

Software Version

07/2021

Last Calibration Date

Simubox Details

8818965

Production number

1.00.01

Software Version

07/2021

Last Calibration Date

13.09.2021

Date



Operator's Sign

Inspector's Sign

Overall results:

The achieved test results show that the instrument is completely functional, and the measuring results lie within +/- 1% of the original calibration. ¹⁾

The calibration of the Fieldcheck test system is fully traceable to national standards.

1) Prerequisite is an additional proof of electrode integrity with a high voltage test.

FieldCheck - Result Tab Transmitter

Customer	Georgian Highlands Region	Plant	Drayton-Lagoon
Order code		Tag Name	
Device type	PROMAG 53 W DN200	K-Factor	1.0526 - 1.0526
Serial number	L81D5519000	Zero point	4
Software Version Transmitter	V2.03.00	Software Version I/O-Module	V1.06.00
Verification date	13.09.2021	Verification time	13:36

Verification Flow end value (100 %): 452.389 m3/h
Flow speed 4.00 m/s

Passed / Failed	Test item	Simul. Signal	Limit Value	Deviation
	Test Transmitter			
✓	Amplifier	22.619 m3/h (5%)	1.50 %	0.03 %
✓		45.239 m3/h (10.0%)	1.00 %	0.06 %
✓		226.195 m3/h (50.0%)	0.60 %	0.06 %
✓		452.389 m3/h (100%)	0.55 %	0.03 %
✓	Current Output 1	4.000 mA (0%)	0.05 mA	-0.001 mA
✓		4.800 mA (5%)	0.05 mA	-0.001 mA
✓		5.600 mA (10.0%)	0.05 mA	-0.012 mA
✓		12.000 mA (50.0%)	0.05 mA	0.000 mA
✓		20.000 mA (100%)	0.05 mA	0.002 mA
—	Pulse Output 1	---	---	---
		Start value	Limits range	Measured value
	Test Sensor			
✓	Coil Curr. Rise	13.300 ms	0.000..27.625 ms	16.425 ms
✓	Coil Curr. Stability		---	---
✓	Electrode Integrity	mV	0.0..300.000 mV	0.000 mV

Legend of symbols

✓	✗	—	?	!
Passed	Failed	not tested	not testable	Attention

FieldCheck: Parameters Transmitter

Customer	Georgian Highlands Region	Plant	Drayton-Lagoon
Order code		Tag Name	
Device type	PROMAG 53 W DN200	K-Factor	1.0526 - 1.0526
Serial number	L81D5519000	Zero point	4
Software Version Transmitter	V2.03.00	Software Version I/O-Module	V1.06.00
Verification date	13.09.2021	Verification time	13:36

Curent Output	Assign	Current Range	Value 0_4mA	Value 20 mA		
Terminal 26/27	VOLUME FLOW	4-20 mA activ	0.0 m3/h	200.00 m3/h		
Pulse Output	Assign	Pulse Value	Output signal	Pulse width		
Terminal 24/25	OFF	---	---	---		

Actual System Ident.

125.0

**2021 Annual Performance Report
Mapleton Water Pollution Control Plant
ECA# 1391-B38PLA August 2, 2018**

Appendix D

Bypass/Overflow/Spill Incident Report

2021

From: [Melissa Cortes](#)
To: moe.sac.moe@ontario.ca; Ec.FA-LP-On.ec@canada.ca; "Neubrand, Rick (MECP)"; smattina@mapleton.ca; jgrose@mapleton.ca
Cc: [Don Irvine](#); [Karen Lorente](#); [Michelle Neal](#); [Richard Junkin](#); [Karla Young](#); [Dwight Hallahan](#); [Dan Yake](#); [Steve Miller](#)
Subject: RE: Drayton Lagoon - Environmental Incident Ref.#1-ICVGP
Date: June-24-21 10:56:00 AM
Attachments: [Drayton Lagoon - Environmental Incident Report - 1-ICVGPP Jun 15, 2021 .pdf](#)
[CofC CA12612-JUN21.pdf](#)
[Report CA12612-JUN21.pdf](#)
[image001.jpg](#)

Good morning,

Please find attached sample results for sample taken June 15, 2021 with regards to the raw sewage spill at the Drayton Lagoon incident 1-ICVGP.

On Friday June 18, 2021 the gravel was scrapped off, disposed of and replaced.

On Monday June 21, 2021 Foster's was onsite and cleaned out the manhole (approx. 3 foot depth) for repairs to be made next day.

On Tuesday June 22, 2021 Wellington Construction was onsite and completed installation of new air relief/back valve and ball valve in the manhole.

Repairs have been completed and a semi-annual maintenance work order has been initiated for the operator to lift the tops of the chamber as well as any other chambers within the system to check equipment inside and have chambers cleaned out if required.

If any further information is required please let me know.

Thank you in advance,

Melissa Cortes

Process & Compliance Technician
Highlands Hub, Georgian Highlands Region
300 Centennial Road
Shelburne ON, L9V 3Z4
519-938-6909



From: Melissa Cortes
Sent: June-16-21 1:04 PM
To: moe.sac.moe@ontario.ca; Ec.FA-LP-On.ec@canada.ca; 'Neubrand, Rick (MECP)'

<Rick.Neubrand@ontario.ca>; smattina@mapleton.ca; 'jgrose@mapleton.ca'
<jgrose@mapleton.ca>

Cc: Don Irvine <DIrvine@ocwa.com>; Karen Lorente <KLorente@ocwa.com>; Michelle Neal <MNeal@ocwa.com>; Richard Junkin <RJunkin@ocwa.com>; Karla Young <KYoung@ocwa.com>; Dwight Hallahan <DHallahan@ocwa.com>; Dan Yake <DYake@ocwa.com>; Steve Miller <SMiller@ocwa.com>

Subject: Drayton Lagoon - Environmental Incident Ref.#1-ICVGP

Regarding: Written Notification concerning the Drayton Lagoon Spill on June 15, 2021.

SAC Reference Number: 1-ICVGP

Date: June 15, 2021

Facility: Drayton Lagoon (Moorefield)

Location: 7101 Sideroad 15, Mapleton

Time Started: June 15, 2021 at 10:06AM

Time Ended: June 15, 2021 at 2:00 PM

Duration of Incident: 4 hours

Contents of Spill: Raw Sewage

Volume: 75.71 Litres (approx. 20 gallons)

Location of Release: Onto gravel driveway and grass beside driveway

Description of Incident/Reason for Spill: Rotted air relief valve within a manhole located between the driveways of the farmer and the lagoon access which caused raw sewage to collect in the manhole and spill.

Actions Taken: OCWA collected 3 PET bottles of material to have analyzed as per ECA influent sampling parameters. Foster's Sewer Service sucked out the manhole chamber, ball valve was located and was able to be closed to reduce flow by 98%. There is still some liquid coming out of the valve but is being contained in the manhole chamber. OCWA operator will check levels of chamber to see approximately how long before the chamber will fill and have to be sucked out again. Wellington Construction is locating a replacement for the air relief valve and ball valve.

Samples Collected: Samples taken at site where sewage came up through manholes spilled onto driveway and are being analysed for parameters according to ECA for influent parameters BOD5, TSS, TP and TKN

Reporting: Operator notified Senior Operations Manager of possible spill on June 15, 2021 at 10:06 AM. MECP Inspector was informed June 15, 2021 at 11:29 AM and given update on June 15, 2021 at 4:04PM. SAC notified on June 15, 2021 at 11:45 AM of spill and was given update on June 16, 2021 at 10:56AM.

Please find attached the Environmental Incident Report. An abatement plan will follow that will detail clean-up efforts. Laboratory results from the samples taken will be forwarded when received.

Have a great day,

Melissa Cortes

Process & Compliance Technician

Highlands Hub, Georgian Highlands Region

300 Centennial Road
Shelburne ON, L9V 3Z4
519-938-6909



Ontario Clean Water Agency Environmental Incident Report

Facility ID: 6093 EIncidentReport
Facility Name: Drayton Wastewater Treatment System & Lagoon
Address: 7101 Sideroad 15
City: Mapleton
Province: Ontario
Postal Code: N0H
Date of Occurrence: 06/15/2021
Time of Occurrence: 10:06:08 AM

Nature of the Incident

Level 1 Contingency Level 2 Contingency Level 3 Contingency [Click here To Show the Definitions](#)

Incident affected: Air Water Land Nothing

What was discharged or emitted?

- | | |
|--|--|
| <input type="checkbox"/> Chlorine | <input type="checkbox"/> Oil/Diesel/Gas |
| <input type="checkbox"/> Sodium Hypochlorite | <input checked="" type="checkbox"/> Untreated or partly treated sewage |
| <input type="checkbox"/> Calcium Chloride | <input type="checkbox"/> Odours |
| <input type="checkbox"/> Aluminum Compounds (Specify in Other) | <input type="checkbox"/> Water |
| <input type="checkbox"/> Arsenic | <input type="checkbox"/> Iron Coagulants |
| <input type="checkbox"/> Fluoride | |

Other: _____

If this was a discharge, spill or emission...

If a liquid, approximately what quantity was released?: 75.71 Litres

If a gas, approximately what quantity was released?: _____

If a solid, approximately what quantity was released?: _____ Kg

What was the source of release?:

Rotted air relief valve within a manhole located between the driveways of the farmer's field and the lagoon access.

Where did the release go?:

Onto the gravel driveway and grass beside driveway

If it entered a watercourse: Yes No

If it went off site: Yes No

Duration of the release?: 4 hours

Is the release now stopped?: Yes No

Was there any damage? (i.e. property and/or environmental): Yes No N/A

If "Yes", describe below and fill out "Insurance Claim" report

Action(s) Taken

What actions were taken to control the incident?

OCWA collected 3 PET bottles of material to have analyzed as per ECA influent sampling parameters. Foster's Sewer Service sucked out the manhole chamber, ball valve was located and was able to be closed to reduce flow by 98%. There is still some liquid coming out of the valve but is being contained in the manhole chamber. OCWA operator will check levels of chamber to see approximately how long before the chamber will fill and have to be sucked out again. Wellington Construction is locating a replacement for the air relief valve and ball valve.

What actions have been taken to remediate the incident?

OCWA has generated a semi-annual maintenance work order that will require the operator to lift the tops of that chamber as well as any other chambers within the system to check equipment inside and have the chambers sucked out if required.

Was this a reportable spill or discharge?: Yes No

If "Yes", at what time was it first reported to the MOE?

via email June 15, 2021 at 11:29am, with follow-up/update discussions and emails

Was it reported to the MOE district office?: Yes No

If "Yes", which office/location and who was the contact?: Guelph District Office - Rick Neubrand

Was it reported to MOE SAC?: Yes No

If "Yes", at what time was it reported to MOE SAC?:

June 15, 2021 at 11:45am - Brenda Catiotti

Was it reported to Municipality?: Yes No

If "Yes", at what time was it reported to Municipality?:

Municipality notified OCWA of spill

External Assistance/Involvement

Was corporate or area office assistance requested?: Yes No

If "Yes", was it received?: Yes No

Was external emergency assistance requested?: Yes No

If "Yes", from who?: Fire Department Equipment Suppliers Canutec
 Ambulance or Hospital MOE Coast Guard
 Police Municipality

Other: _____

Was there any media involvement?: Yes No

If "Yes", who?: _____

Was the public affected?: Yes No

If "Yes", how?: _____

Updated By: Melissa Cortes 06/16/2021 12:43:43 PM

Comments: